



BIDS AND AWARDS COMMITTEE  
**Supplemental Bid Bulletin No. 01**

***Supply and Installation of One (1) Brand New 175Kva Silent Type Diesel Generator Set with Automatic Transfer Switch including Housing, Pad and Accessories (Lot)***

WGP Conference Room  
7 March 2018

This Supplemental Bid Bulletin No. 01 is issued to clarify, modify or amend some provision/s in the bid documents, to wit:

1. On Section VII. Technical Specifications: Item 1
  - Change 24 Voltage Maintenance Free Battery to 12-24 Voltage depending on the brand name to be offered
  - Instead of 175kVA use 165kVA for minimum capacity
  - Engine, Alternator and Controller must be all OEM (Original Equipment Manufacturer)
  - Use NEMA 3R for outdoor installation
2. On Section VII. Technical Specifications: Item 4
  - See attach model design for the generator power house
3. Test Requirements
  - 4-hour Warehouse Testing prior to delivery or Onsite Load Testing, fuel to be provided by Supplier
4. Other Requirements (Eligibility of Suppliers)

*Prospective bidder shall be PCAB Licensed Contractor commensurate to the category of the proposed project and must be in the industry of similar nature for at least 3 years.*

  - Instead of “*and must be in the industry...*” change it to “*or must have an ample experience in the industry.*”

This **Supplemental Bid Bulletin No. 01** shall form part of the Bidding Documents. Any provision in the Bidding Documents inconsistent herewith is hereby amended, modified or superseded accordingly.

For information and guidance of all concerned.

**ANITA E. GORGONIO**  
Chairperson  
Bids and Awards Committee

**MODEL DESIGN OF POWER HOUSE**

